

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45219CO	03A0548CO	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 89-63 163rd Street Queens NY	Hold	\$0.00
Carry over from September 17, 2003 meeting.						
45668CO4	04A0195CO4	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Bloomberg 731 Lexington Avenue New York NY	Approved	\$0.00
Carry over from 5/19/04 meeting.						
45986CO	04A0464CO	Vista Electrical Contractors, Inc. 2377 Washington Avenue Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	Jewish Home and Hospital 100 West Kingsbridge Road Bronx NY	Approved	\$0.00
Carry over from November 17, 2004 meeting.						
45987CO	04A0465CO	Lippolis Electric, Inc. 445 Fifth Avenue Pelham NY 10803	Requested approval for the electric service equipment proposed to be installed	Jacob Nursing Home 1160 Teller Avenue Bronx NY	Approved	\$0.00
Carry over from November 17, 2004 meeting. Show ungrounded generator. Item finalized Januray 5, 2005.						
45994CO	04A0472CO	AC Electrical Services, Inc. 142 West 19th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	20-22 Mercer Street New York NY	Approved	\$0.00
Carry over from November 17, 2004 meeting.						

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46028CO	CO	altPower, Inc. 160 Fifth Avenue, Suite 807 New York NY 10010	Requesting permission to allow the installation of custom laminated photovoltaic (PV) Modules that are not listed by a nationally recognized testing laboratory but are built to UL 1703 standard.	The Helena 601 West 57th Street New York NY	Denied	\$0.00
Carry over from November 17, 2004 meeting. All components must be listed and approved by a nationally recognized testing laboratory.						
46043CO	04A0506CO	Herman Miller, Inc. P.O. Box 302 Zeeland MI 49464	Requested approval for use in New York City of your Ceiling Level and Power Distribution System. Model/Series No. USL-E230973 components 277/120 volt Relay/Dimmer Module 1B11Y4.		Approved	\$0.00
Carry over from November 17, 2004 meeting. Installation instructions must include a statement that the installation must comply with New York City Article 604.						
46048	04A0510	Fred Geller Electrical, Inc. 37-32 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The Hearst Building 959 Eighth Avenue New York NY	Hold	\$650.00
1) Provide overall emergency system one-line diagram (composite by ASCO?) show same 1-Line on Lincoln drawings. 2) Provide trip unit settings for all breakers in paralleling switchgear. 3) Provide generator short circuit information. 4) Comply with rule 12-01 for location of transfer switches.						
46049	04A0513	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	NYU HCC 550 1st Avenue New York NY	Approved	\$650.00
46050	04A0518	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Stop & Shop Supermarket 2754 Hylan Blvd. Staten Island NY	Ok, but	\$650.00
1) Fire alarm tap must be direct service tap to fuse cut-out. 2) Standby generator not suitable for emergency loads. 3) Confirm Article 110 clearances in service room with gas generator.						

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46051	04A0519	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	UJA-Federation of NY 130 East 59th Street New York NY	Approved	\$650.00
1) Bus undersized in Switchboard A, 4000A service switch and Switchboard B, 4000A service switch. 2) Close off rear access behind service switchboards. 3) Rear accessible switchboards (DP-A) shall have hinged rear doors. Item finalized 2/28/05.						
46052	04A0521	The Electric Connection Inc. 410 West 127th Street New York NY 10027	Requested approval for the electric service equipment proposed to be installed	Kennedy House 110-11 Queens Blvd. Queens NY	Approved	\$650.00
Provide dimensioned floor plan. Job finalized 4/26/05.						
46053	04A0522	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Memorial Sloan Kettering  New York NY	Approved	\$650.00
46054	04A0523	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	New Water Street Corp. 55 Water Street New York NY	Hold	\$650.00
Provide short circuit and coordination study.						
46055	04A0531	Livingston Electrical Associates, Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	400 West 55th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46056	04A0536	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	AABCO/ASM 47-40 Metropolitan Avenue Ridgewood NY	Approved	\$650.00
46057	04A0537	AMC Electrical Services, Inc. 3819 Fort Hamilton Parkway Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	9 East 40th Street New York NY	Approved	\$650.00
46058	04A0543	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	New York Life 51 Madison Avenue, 26th Floor New York NY	Approved	\$650.00
1) Increase conductors on load side of transformer to 2 sets of 500 MCM. 2) Remove building steel bond in 800 amp disconnect switch. 3) Provide bus size in new switchboard. Item finalized 12/30/04.						
46059	04A0544	A.T. Baker Electrical Consulting, Inc. P.O. Box 226 Glen Head NY 11545	Requested approval for the electric service equipment proposed to be installed	1350 6th Avenue New York NY	Approved	\$650.00
46060	04A0553	Olympic Electrical Wiring Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	West Brighton Houses 230 Broadway Staten Island NY	Approved	\$650.00
Provide calculations at point A (line side of panelboard), and location of panelboard. Item finalized January 5, 2005.						

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46061	04A0554	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Queens Hospital Center 82-50 164th Street Queens NY	Approved	\$650.00
46062	04A0511	A & A Electrical Contracting Corp. 471 Van Brunt Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	New York Community Hosp. 2525 Kings Highway Brooklyn NY	Approved	\$650.00
46063	04A0512	atchtower Bible and Tract Society of NY I 25 Columbia Heights Brooklyn NY 11201	Requested approval for the electric service equipment proposed to be installed	77 Sands Street Brooklyn NY	Approved	\$650.00
46064	04A0516	Rothstein & Hoffman Electric 255 Centre Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Gen Kin Plaza 37-02 Main Street Flushing NY	Approved	\$650.00
46065	04A0520	Judd Electric, Inc. 1097 Second Avenue, Suite 300 New York NY 10022	Requested approval for the electric service equipment proposed to be installed	263 West End Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46066	04A0524	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	New Water St. Corp. Site 18B 211 North Ened Avenue New York NY	Ok, but	\$650.00
Provide room layout.						
46067	04A0525	Gessin Electrical Contractors, Inc. 791 East 139th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	18-20 West Street New York NY	Approved	\$650.00
46068	04A0526	M & M Control Wiring Inc. 227 Wellbrook Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	331 Madison Avenue New York NY	Approved	\$650.00
46069	04A0527	Associated Electrical Contrs of NY Corp. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	550 Greene Avenue Brooklyn NY	Approved	\$650.00
46070	04A0528	Engineering Services Associates, P.C. 875 Sunrise Highway (West Office) Lynbrook NY	Requested approval for the electric service equipment proposed to be installed	60 Thompson Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46071	04A0529	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	31 West 15th Street New York NY	Approved	\$650.00
46072	04A0530	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	4901 Henry Hudson Parkway Bronx NY	Approved	\$650.00
46073	04A0532	New Century Electrical Contracting Inc. 3231 Ampere Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	Paradise Theater 2401 Grand Concourse Bronx NY	Approved	\$650.00
Check size of RHH wire for a fire pump. Sign on doors. Item finalized 12/30/04.						
46074	04A0533	Izzo Electric Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	760 Melrose Avenue Bronx NY	Approved	\$650.00
46075	04A0534	Izzo Electric Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	1011 Washington Avenue Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46076	04A0535	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Rockefeller Center-Obser. Plz 30 Rockefeller Plaza New York NY	Approved	\$650.00
46077	04A0542	Discover Electric Co., Inc. 58-10 58th Place Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	1971 Webster Avenue Bronx NY	Approved	\$650.00
46078	04A0541	A.J. Ianni Electrical Contractor 1402 B Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	315 Park Avenue South New York NY	Approved	\$650.00
46079	04A0540	A.J. Ianni Electrical Contractor 1402 B Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	1695 Eastchester Road Bronx NY	Approved	\$650.00
46080	04A0539	A.J. Ianni Electrical Contractor 1402 B Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	130 Water Street New York NY	Approved	\$650.00



# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46081	04A0538	Hugh O Kane Electric Co., Inc. 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Cornell University 516 East 72nd Street New York NY	Approved	\$650.00
46082	04A0545	United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	1 East 42nd Street New York NY	Approved	\$650.00
46083	04A0546	A to Z Electrical Maint. & Serv. Corp. 307 Seventh Avenue, Suite 403 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	438 West 19th Street New York NY	Hold	\$650.00
1) Show short circuit calculations. 2) Show coordination 800 amp service switch and meter bank. 3) Fuses do not coordinate 1200 amp and 400 amp.						
46084	04A0547	CHT Electrical Corp. 535 5th Avenue, 33rd Floor New York NY 10017	Requested approval for the electric service equipment proposed to be installed	510 6th Avenue New York NY	Approved	\$650.00
46085	04A0548	Excello Electl Constn & Maint. Co., Inc. 525 Broadway New York NY 10012	Requested approval for the electric service equipment proposed to be installed	581 Broadway New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46086	04A0549	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2000 Gun Hill Road Bronx NY	Approved	\$650.00
46087	04A0550	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	16-66 Bell Blvd. Bayside NY	Approved	\$650.00
46088	04A0551	D.J. Electrical Contractors Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	519 8th Avenue New York NY	Approved	\$650.00
46089	04A0552	Joma Electrical Contracting Co., Inc. 218 31st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	430 Maspeth Avenue Brooklyn NY	Approved	\$650.00
46090	04A0557	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Marriot Time Square Hotel 1021-1029 Avenue of the Americas New York NY	Hold	\$650.00
Need revised drawings.						

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46091	04A0558	Windsor Electrical Contracting, Inc. 116-03 Metropolitan Avenue Kew Gardens NY 11418	Requested approval for the electric service equipment proposed to be installed	37 West 26th Street New York NY	Approved	\$650.00
One time, one location.						
46092	---	Consolidated Edison Company 4 Irving Place New York NY 10003	Requesting permission to split up an existing Con-ED loop service by installing a standpipe service in a building located in the middle of the loop.	Loop Services 45-23 171 Street Queens NY	Approved	\$0.00
One time, one location.						
46093	-----	FMC Associates Consulting Engineers 261 West 35th Street New York NY	Requesting permission to install one 30 amp 208 volt receptacle in the laundry area to power a stackable electric washer, dryer appliance and omit the 20 amp, 120 volt receptacle requirement.	155 West 21st Street New York NY	Approved	\$0.00
One time, one location.						
46094	0	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission due to hardship to replace to leave as installed wire mold installed on the floor that is not subject to mechanical injury.	875 Third Avenue, 29th Floor New York NY	Approved	\$0.00
With the stipulation that all of the unused receptacle are capped off.						
46095	00	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requesting permission to leave as installed service equipment for a cell site that is not grouped together with the existing service equipment.	420 Manor Road Staten Island NY	Approved	\$350.00
With the stipulation that signage is provided at each service indicating where the other service is located.						

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46096	00	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requesting permission to leave as installed service equipment for a cell site that is not grouped together with the existing service equipment.	144-43 Farmers Blvd. Jamaica NY	Denied	\$350.00
The service switch shall be grouped together with the existing service equipment. See Section 230.72 of the National Electrical Code.						
46097	000	John A. Di Bari, P.E. Consulting Eng. 99 Main Street Dobbs Ferry NY 10522	Requesting permission to leave as installed a multi-dwelling building that was rewired under the old New York City Electrical Code without balcony receptacles.	146-148 West 22nd Street New York NY	Denied	\$0.00
Bulletin #144.1 requires that receptacles with ground fault protection must be installed on all balconies in multi-family buildings.						
46098	0000	C.M. Richey Electrical Contractors 712 Fifth Avenue Brooklyn NY 11215	Requesting permission due to lack of room inside the building to leave as installed service equipment located on the outside of a commercial building.	KFC/Long John Silvers 154-08 Northern Boulevard Queens NY	Denied	\$350.00
Section 230.70(A) of New York City's amendments to the National Electrical Code requires the service disconnecting means to be installed inside the building or structure at the nearest point of entrance of the service conductors.						
46099	0000	Salzman Electric Inc. 208-05 35th Avenue Baysided NY 11361	Requesting permission to leave as installed and not file Advisory Board drawings on a installation where the second fusing was changed from 100 to 125 amps on a service rated over 1000 KVA.	Limpe Residence 262 Central Park West, Apt. 13E New York NY	Denied	\$0.00
Section 110.2(B)(2) of New York City's amendments to the National Electrical Code require that Advisory Board drawings must be submitted for any change on the first and second fusing on a service rated 1000 KVA or larger.						
46100	0000	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requesting permission to install Vita Link MC Fire rated cable that is not approved for Class 1 Division 1 locations to be used as a temporary wiring method in a Class 1 Division 1 location inside of a Manhattan pump station.	NYC Dept. of Environ. Protect. 13th Street and Avenue D New York NY	Approved	\$0.00
With the stipulation the stipulation that the Vita Link MC fire rated cable is not installed in a Class 1, Division 1 location.						

# ADVISORY BOARD CALENDAR

**December 15, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46101	00000	UL Electrical Corp. 115-05 Liberty Avenue, 2nd Floor Richmond Hill NY 11419	Requesting permission on an Advisory Board drawing, Cal #45742 status 'ok, but' to build a separate room containing the automatic transfer switch for life safety inside of the electrical service room.	470 Lefferts Avenue Brooklyn NY	Approved	\$0.00
With the stipulation that the new room and door are fire rated.						
46102	04A0514	Roman Fountains Box 10190 Albuquerque NM 87184	Requested approval for use in New York City of your Submersible Niche Fixture Assembly. Model/Series Numbers: AFL-EN Series.		Denied	\$200.00
Does not comply with New York City Electrical Code Amendment 680.51(B).						
46103	04A0515	Bain Ultra 956 Chermin Olivier St. Nicolas, Quebec CD G7A2N	Requested approval for use in New York City of your Hydromassage Bathtub.		Approved	\$200.00
46104	04A0517	Lutron Electronics Co., Inc. 7200 Suter Road Coopersburg PA 18036	Requested approval for use in New York City of your Digital Ballast Control.		Hold	\$200.00
Ballast must be listed						
46105	04A0555	Dynamic Ballast Corp. 41 Smith Street Englewood NJ 07631	Requested approval for use in New York City of your Electronic Fluorescent Ballasts. Model/Series Nos. DY132IS120, DY232IS120, DY332IS120, DY432IS120, DY132IS277, DY232IS277, DY332IS277, DY432IS277, DY132ISWV, DY232ISWV, DY332ISWV and DY432ISWV.		Approved	\$200.00

# ADVISORY BOARD CALENDAR

December 15, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46106	04A0556	Best Lighting Products 6775 Speedway Blvd., Ste 107 Las Vegas NW 89115	Requested approval for use in New York City of your Emergency Ballast. Model/Series Nos. BAL50, BAL60, BAL100 and BAL94C.		Approved	\$200.00