

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
	14A0142CO3	Requested approval for the electric service equipment proposed to be installed	Denied	\$0.00
Carry over from November 19, 2014 meeting. Sync board is not code compliant and unsafe.				
52904	14A0310CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from June 11, 2014 meeting. 1) Grounding of existing switchboard not shown, bonding jumper sizes not shown. 2) Due to the design change of the job causing extra new equipment can a 2nd door be added to the service room or can the existing door open outwards w/panic hardware. 3/30/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52667	14A0340	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52699	14A0354	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52700	14A0397CO2	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from November 19, 2014 meeting. With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.                      Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/31/17 Verify existing 2500 kva transformers, an-1 &amp; an-2 neutrals is not bonded &amp; grounded at the transformer 3/1/17 - new drawings provided showing bonding and grounding. 3/2/17 - swap dwg #D rev 3 dwg # F rev 2 &amp; dwg G Rev 1 11/14/17 swap dwg B rev 2, C - Rev 1, D-Rev 4, E-Rev 5, F-Rev 3 &amp; G-Rev 2</p>				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
52701	14A0411CO	Requested approval for use in New York City of your CellCube Vanadium Flow Battery. Model/Series Numbers: FB30-130.	Approved	\$0.00
Carry over from August 13, 2014 meeting. For Cellcube Models FB-10, FB-20, and FB-30 storage battery's only. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	14A0443	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) ATS' not to be installed in service room. 2) Feeder to elevator # overfused, and EGC is undersized. 4/21/15 Rejected Equipment grounding conductors undersized for 125 and 200 amp feeders, see Table 250.122. 4/24/15 Rejected 125 amp feeder is still undersized. 8/13/15 Denied 3rd revision submitted and reviewed. 1) #3 awg conductor fused at 200 amps on emergency side. 2) Horsepower of elevator is not provided to determine proper fusing for elevator #8. New submittal required.				
52966	14A0476	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide 2nd set of generator, short circuit curves, circuit breakers, reduced neutral calculations. 2) Transformer cut sheets showing listing not provided. 3) Lengths of transformer secondary's not shown. 4) Time current curve shows no coordination. 5) Drawing D-Tapped 750KCM conductor undersized to 400 amp Trans-S. 4/7/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 4/18/2017 - 1) comply section 230.42 (A) for service equipment bus size. Vertical bus for ss#5 undersize (dwg B1) 2) Dwg -D1 comply section 695.5 (A) for x'mer over current protection and feeder size. Over current prot' and feeder at the em generator side is undersize. 6/14/17 Swapped drawing B1-Rev-5 and drawing D1-Revision 4 11/21/17 - swap dwgs A - Rev 1, A1 - Rev 2, B Rev 1, B1 Rev 6, C1 Rev 3, D rev 2, D1 Rev 5, E Rev 8, E1 Rev 3. 9/18/18 Swap dwg #A-Revision 2; dwg A1--Revision 3; dwg B-Revision 2; dwg B1--Revision 7; dwg C-Revision 1; dwg C1-Revision 4; dwg D-Revision 3; and dwg D1-Revision 6.				
	14A0496CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carry over from September 10, 2014 meeting. 1) Drawings show coordination, but short circuit study doesn't, normal load and emergency feeders to ATS #2 show as 600 MCM on 1 Line and listed as 300 MCM on coordination study page 24 of 85. 2) New service switch don't comply with 230.64(B), due to room layout drawing changes. What kind of equipment is installed in front of the service switch?				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
52898	14A0533	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) CSA markings on product to be CSA US listed. 2) Coordination study to be performed by a P.E. bearing the stamp. 3) Provide 36" side access for T1/P1 and T2/P2. 4) Indicate normal position of tie breakers. 5) Provide 15KV switchgear cuts. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/27/18 - swap dwg 2 of 3 Rev 2</p>				
52702	14A0557	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	14A0594	Requesting permission to leave as installed due to a hardship to replace, an open bottomed 3000 amp fused switch feeding an open bottomed 3000 amp switchboard with 11-4 inch conduits containing 5-500 KCM conductors with 1-500 KCM as an equipment grounding conductor connected directly to the enclosures on each side, where 3/0 equipment bonding jumpers are installed on the conduit bonding bushings to the enclosures.	On Hold	\$350.00
<p>This special permission request must be accompanied by a letter from DCAS Electrical Engineering department agreeing with this request.</p>				
52884	14A0611	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide additional copies of short circuit study and generator information. 2) Wiring method from 1200 amp service switch to retail trough not shown, feeder size not shown. 3) Equipment grounding conductors from retail trough to disconnect switches undersized. 4) Equipment grounding conductors undersized on load side of 800 Trans-S for fire pump feeders normal and emergency sides. 5) Show conductor size to 30 amp fuse pullout. With the stipulation: that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/24/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
	14A0621	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Drawings not in Advisory Board format. 2) Coordination study not provided. 3) Verify that all equipment and shredder are listed by NRTL. 4) No bus sizes DM from clearances etc.				
52880	14A0627	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Grounding electrode conductor for fire pump undersized and emergency feeder underfused. 2) Is generator new or existing? 3) With the stipulation: Fire Rated Enclosure's must comply with the following:                      1.A P.E. or R.A. must file a PW1 as an ALT 3.                      2.A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.                      3. The fire proofing must be performed by a certified fire proofing installer. 3/24/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Fire Rated Enclosure's must comply with the following:                      1)A P.E. or R.A. must file a PW1 as an ALT 3.                      2)A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.                      3)The fire proofing must be performed by a certified fire proofing installer.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/20/15 Swapped drawing 1,2 and 3-Revision 4s. 2/22/16 Swapped drawing 1,2 and 3, Revision 5s. 3/9/18- swap dwg with Rev 6 NO MORE SWP</p>				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
	14A0632	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
<p>1) Block off rear of switchboard TDB. 2) Provide 2nd copy of generator information. 3) Provide mechanical ventilation in service room. 4) Verify that there is a load shed scheme for generator, may be undersized. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/1/15 Job finalized. With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DaB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 9/27/17 - Verify complying with section 110.26(A)(3)</p>				
52663	14A0636	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/28/17 - swap dwg # A rev -1				
52664	14A0637	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/15/16 Swapped drawing A, Revision 1.				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
	14A0670	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) 1 Line drawing not in Advisory Board format, bus sizes not shown. 2) Are ATS' 3 or 4 pole types. 3) Where are generators located? No room layout provided. 4) If Switchboard is prefabricated and prewired, it must be listed by a NRTL. as a complete assembly-switchgear, wiring and enclosure. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
	14A0671	Requesting permission to leave as installed unprotected transformer secondary conductors or to install secondary protection that will not comply with 240.24(A) but will allow for the fused switch to be operated by a Hookstick.	On Hold	\$350.00
Code: 240.21(c). Provided electrical room layout drawing showing elevations and accessibility of disconnect switches.				
52703	14A0672	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Note: Issues after 2nd fusing. 1) Feeder not derated are 2 conduits being installed. 2) All equipment to be listed. 3) Subject to Con-Ed approval. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
52893	14A0673	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) 2nd fusing off of 1200 amp s.s #3 not shown. 2) With the stipulation: that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/26/15 Job finalized. This job approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	14A0675	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Bonding and grounding of new and existing equipment not shown. 2) Incoming fault current not shown. 3) Verify that service room is 2 hour fire rated. 4) Coordination between new switch and panelboard not shown. 5) 2 copies of full size drawings required. 6) Why is material submittal sheet included in this submittal, equipment is approved.</p>				
52874	14A0676	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide sequence of operation. 2) Remove grounding from TRX. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	14A0677	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Rear of switchboard to comply with 408.60F, rear hinged doors, drawings conflict with cutsheets. 2) Verify that transformed is listed. 3) Rear clearances to comply with Table 110.34A. 4) Sequence of Operation not provided. 5) Are PT's connected on cable tied? 6) How long are the transformer secondary taps? 7) Vertical bus undersized in switchboard. 8) Comments on drawing indicate 277/480 volts. 9) Review not complete.</p>				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
	14A0681	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Fire pump service switch not shown in service room. 2) Size on main bonding jumpers not shown. 3) 200 amp meters and service switches reversed. 4) FLA of fire pump not shown. 5) Is generator a separately derived system neutral in generator is not bonded but disconnect switches are. 6) Generator cut sheet no provided, verify listing. 7) Panel QMB overfused. 8) Verify 3/0 conductors feeding 30 amp fire alarm switch. 9) Jockey pump tap must be relocated. 10) Provide documentation for meterbanks and s.s. as series rated. 11) Clarify what is D phase in general notes. 12) Plan not clear, many drafting errors. 1) Fire pump equipment grounding conductor undersized. 2) Fire pump feeder to be fire rated, note on drawing not clear. 3) Explain 9 sets of (4) 500 KCM in 3 1/2" conduit. 4) Short circuit study must be performed. 1/22/16 Denied 1) Fire pump equipment grounding conductor undersized. 2) Fire pump feeder to be fire rated, note on drawing not clear. 3) Explain 9 sets of (4) 500 KCM in 3 1/2" conduit. 4) Short circuit study must be performed, signed and sealed by a P.E. No copies. Job to be refiled.</p>				
52890	14A0682	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Tap of a tap is not permitted on load side of 1200 amp service switch. Connect 400A switches independently to tap point. 2) Per 705.12.D.2 conductors feeding existing panel A and bus in panel A are undersized. 3) Confirm selective coordination of elevator circuits per 620.62. 3/24/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/23/16 Swapped drawings 2 and 3 of 3-Revision 1.</p>				
52666	14A0685	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				



# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
52889	14A0686	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Show generator fault current . This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/24/25 Job finalized With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.                      Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/26/15 Swapped drawing 1, Revision 2.</p>				
52895	14A0690	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Service switch cond undersized for s.s. #1 and F.P. and F.A. 3/27/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/22/16 Swapped drawing ME-26 sheet 1 of 1-Revision 1.</p>				
	14A0691	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>Drawings not in Advisory Board format information not complete.</p>				
	14A0693	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Verify whether 900 or 600 KCM service entrance conductors will be installed, match drawing 2 of 4 with 3 of 4 and 4of 4. 2) Verify that cellar floor is directly below 1st floor. 3) Service switch sizes not shown on 1 Line drawings. 4) Indicate on room layout drawing which cabinet the service entrance conductors are entering. 5) Show length of tap from s.s. #B1 to apartment meterbank distribution panel. 6) Service "A" 60 amp fire alarm switch fused at 100 amps. 7) Transformer cut sheets showing listing not provided. 8) Ground fault protection not shown for transf secondary.</p>				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
52704	14A0694	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52705	14A0696	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52875	14A0700	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Equipment ground conductor to fire pump undersized, load side of ATS. 2) Generator frame to be grounded. 3) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/23/15 Job finalized. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> <p>1/3/18 - Swap dwg 1 &amp; 2 Rev 1</p>				
52900	14A0701	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) 1/0 tap conductors undersized. 2) Confirm that all trough taps are within loft. 3/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
	14A0703	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
Provide documentation (basement) indicating this building and 90 Lexington Avenue are considered one property and same ownership. 4/7/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/22/16 Denied. Many changes on drawing are not indicated drawing to be resubmitted and completely reviewed.				
	14A0704	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
Provide documentation (basement) indicating that this building and 88 Lexington Avenue considered one property and same ownership. 4/7/15 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/22/16 Denied. Many changes on drawing are not indicated, drawing to be resubmitted and to be completely reviewed.				
52885	14A0706	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Service conductors undersized. 2) Provide part plan for SEB confirming proximity to service room. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52706	14A0710	Requesting permission to utilize the 2014 NEC to allow the installation of listed 1000 volt solar photovoltaic equipment for 11 locations	Approved	\$0.00
22-29, 22-37, 22-45, 22-51 and 22-59 Dix Avenue and 714 Seneca Avenue-Queens; 2722 East Tremont Avenue and 2049 Buhr Avenue-Bronx; 250 Ocean Parkway, 950 East 14th Street and 3715 Kings Highway-Brooklyn. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52886	14A0711	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Equipment grounding conductors on line and load side of service switch undersized. 2) Service switch not bonded and grounded. 3) Verify that this submittal is for the service switch only, not second fusing. 4) Bonding and grounding of existing switchboard not shown. 5) Reverse the door swing. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
52665	14A0712	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/7/15 Swapped Drawing Revision 1.				
52707	14A0714	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52668	14A0715	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52734	14A0716	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
52669	14A0717	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52708	14A0718	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52670	14A0719	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
52671	14A0720	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52672	14A0721	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/26/15 Swapped Drawing 1, Revision 1.				
52673	14A0722	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52709	14A0723	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:                      Fire Rated Enclosure's must comply with the following:                      1. A P.E. or R.A. must file a PW1 as an ALT 3.                      2. A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.                      3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/26/18 - swap dwg ACS-D-11324-1,2,3,4,&amp; 5 REV 3</p>				

# ADVISORY BOARD CALENDAR

**December 17, 2014**

Approval #	Submission #	Type of Request	Status	Fee
52674	14A0724	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/22/16 Swapped D-Revision 2				
52710	14A0725	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/15 Swapped Drawing 1, Revision 1. 6/21/16 Swapped drawing 1-Revision 3.				
	14A0726	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not in Advisory Board format.				
52711	14A0727	Requesting permission to install a manufactured wiring system beneath an accessible hung ceiling as an under floor wiring method in a furniture show room.	Approved	\$0.00
Code: 604.1(A)(3). With the stipulation that all components must be part of the listed system and comply with Sections 604.1(A)(1). Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53051	14A0728	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify that service room is mechanically ventilated. 2) Show size of main bonding jumper 3) Provide neutral disc. 4) Verify available short circuit (23.915)? 5) What is D ought? 5/28/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 4/19/19 Swap dwg 1 of 1 rev 2.				
	14A0729	Requesting permission to work on an existing 120/208 volt panel where the front clearance is 34 inches and the bus duct tap box above the panel extends more than 6 inches in front of the panel.	On Hold	\$0.00
Code: Table: 110.26(A) .This special permission request must be accompanied by a letter from DCAS Electrical Engineering department agreeing with this request.				