



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 122-05-E

Manufacturer: Giacomini S.p.A., Via per Alzo, 39, 28017 San Maurizio d'Opaglio -NO- Italy

Trade Name(s): Giacomini

Product: Concealed Siamese connections

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS 17

Prescribed Test(s): Class Number 1530 dated August 1970 (Fire Department Connections)

Laboratory: Factory Mutual Approvals

Test Report(s): FM Approval, Project ID: 3026348, issued May 9, 2006.

Description – Fire department Siamese connections, **Model A101**, size 3" x 3" x 4" straightway pattern and **Model A102**, size 3" x 3" x 4" 90 degree pattern. These fire department connections are intended for exterior installation on buildings having standpipe or sprinkler systems to enable the fire department to connect hose lines directly to the system to supplement the existing water supplies.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated August 9, 2006, F.P. Index #0607061.

Terms and Conditions: The above models are accepted on condition that all:

1. Installation comply with all applicable New York City Building codes, rules, regulations and testing requirements and in particular with the requirements of Title 27, Subchapter 17, Article 3 § 27-951 and RS 17-3 of the Administrative Code.
2. The Siamese connection, when installed, shall be subject to a hydrostatic-pressure test of at least 300 psig for at least one hour.
3. Factory Mutual's listing requirements and limitations shall be complied with.
4. Manufacturer's installation, maintenance and limitations shall be complied with.
5. The condition of approval shall be enumerated in the installation manuals and sales brochures that will be provided to all New York City buyers, users and installers.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance

December 8, 2006

Examined BY

Donald J. [Signature]