

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 139-03-E

Report of Material and Equipment Acceptance Division

Manufacturer – Termet s.a. Elite International Company, Inc., 7909 Melrose Avenue, Los Angeles, California 90046-7109.

Trade Name – Elite USA.

Product – Instantaneous, gas fired water heater.

Pertinent Code Section(s) – 27-800, 27-826, RS 14-2 (ANSI Z223.1).

Prescribed Test(s) – RS 14-6 (ANSI Z21.10.3).

Laboratory – CSA International.

Test Reports – CSA No. 1339650 dated April 16, 2003.

Description – Instantaneous, wall mounted, gas fired hot water heater, model G19-(01,02)NG, designed for indoor installation. Unit comprises main burners, battery powered sparking or hydro-generator powered sparking heater exchanger, built-in draft hood, pilot burner, manual valve, and automatic valve operated by water flow, and a gas pressure regulator. Normal input heating rating of water heater on natural gas is 77,000 BTUH. Water is designed for mounting at the rear to a vertical wall with the following minimum installed clearances to combustible construction: sides - 4 inches front-alcove, top- 12 inches; from single wall flue or vent connection in any direction - 6 inches ; from back of unit (with support bracket) - 0.

Recommendation – That the above described residential water heater, installed as per clearances to combustible construction specified above, be accepted when fired by natural gas only, under the following conditions:

1. Heaters shall not be installed in any enclosed space with a volume of less than 100 cubic feet.
2. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtain from the Bureau of Electrical Control before installation.

Final Acceptance Sep/24/03

Examined by S Dorshidan