

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner  
MEA 14-00-E

Report of Material and Equipment Acceptance Division

Manufacturer - Notifier, 1 Firelite Place, Northford, CT 06472.

Trade Name(s) - ADT, Notifier.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL864.

Laboratory - Underwriters Laboratories, Inc.

Test Report - UL ML File S232, issued November 19, 1998, revised November 22, 1999.

Description - Multiple listing of ADT modules as follows:

Basic Applicant's Notifier, Pittway Co. Product Designation	Multiple Listee's ADT Security Services Inc. Product Designation	Description
FMM-1	M300MADT	Monitor Module
FMM-101	M301MADT	Monitor Module
FSM-101	M300SMADT	Monitor Module
FZM-1	M302MADT	Monitor Module
FCM-1	M300CADT	Control Module
FRM-1	M300RADT	Control Module

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objections letter dated March 23, 2000, F.P. Index No. 9912073A under MEA 457-99-E for equivalent model numbers.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, and the UL Listing. Periodic sensitivity tests where required shall be conducted in accordance with the regulations of the Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance November 29, 2001

Examined By *Mark J. Kelly*