



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 14-06-E Vol. 2

Manufacturer: Goodman Manufacturing, 5151 San Felipe, #500.
Houston, TX 77056

Trade Name(s): Goodman, Amana, Janitrol, GMC.

Product: Air-cooled condensing units
MEA Index #20-20 – Air Conditioning Equipment

Pertinent Code Section(s): 27-770, 27-777.

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-11 (UL 1995).

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): No. 3083-366-002, dated February 2, 2006 and revised November 13, 2007.

Description: Split-system air-cooled condensing units, designed for outdoor installation. R-410A is the refrigerant used for the system. Unit is comprised of air-cooled condenser, direct-driven centrifugal fan, hermetic type compressor and controls. A manually reset-type pressure limiting device is provided with setting at 400 psi, maximum. Units, with model numbers and nominal cooling capacities, are listed below:

Model	Nominal Cooling Capacity (Btu/hr)
ASX180361**	35,000
ASX180481**	47,000
ASX180601**	57,000
GSX130181**	18,000
GSX130241**	24,000
GSX130301**	30,000
GSX130461**	36,000
GSX130421**	42,000
GSX130481**	48,000
GSX130601**	60,000

** -Denotes additional characters (A-Z) designating revisions.

Terms and Conditions: The above described air-cooled condensing units are accepted under the following conditions:

1. Units shall be installed outdoors.
2. Units shall utilize Refrigerant R-410A only.
3. All equipment shall be furnished with permanently affixed metal tags stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be accompanied by a metal tag, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance March 28, 2008

Examined By: Simon Derkhotan