

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 14-07-E

| Manufacturer: | Rheem Manufacturing Co., A/C Division, P.O. Box 17010, Fort Smith, AR 72917-7010 |
|----------------------------|-------------------------------------------------------------------------------------|
| Trade Name(s): | ThermalZone |
| Product: | Outdoor, air-cooled condensers and compressor units |
| Pertinent Code Section(s): | 27-770, 27-777 |
| Prescribed Test(s): | RS 13-11B (ANSI B9.1), RS 13-11A (UL 1995) |
| Laboratory: | Underwriters Laboratories, Inc. |
| Test Report(s): | No. SA7930 dated January 30, 2004 |

Description: Outdoor air-cooled condensing and compressor units, TZAA- series, designed for refrigeration and air conditioning systems. R-22 is the refrigerant used for the system. Unit is comprised of condenser coil, fan motor and appropriate controls. Units, with cooling capacities, are listed below:

| Model No. | Mfr.'s Specified Nominal Cooling Capacity (Tons) |
|-----------|-----------------------------------------------------|
| TZAA-318* | 1.5 |
| TZAA-324* | 2.0 |
| TZAA-330* | 2.5 |
| TZAA-336* | 3.0 |
| TZAA-342* | 3.5 |
| TZAA-348* | 4.0 |
| TZAA-360* | 5.0 |

*Denotes additional characters in model numbers

Terms and Conditions: The above-described air-cooled condensing units are accepted under the following conditions:

- 1. Units shall be installed outdoors only.
- 2. Units shall use Refrigerant R-22 only.
- 3. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
- 4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
- 5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
- All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 1/24/07 Examined By Styram And