



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 145-07-E

**Manufacturer:** Cleveland Range Ltd., 8251 Keel Street, Concord, Ontario L4K 1Z1, CANADA

**Trade Name(s):** Cleveland Range

**Product:** Gas-fired commercial kettles

**Pertinent Code Section(s):** 27-800, 27-826, RS 14-2 (ANSI Z223.1)

**Prescribed Test(s):** RS 14-6 (ANSI Z83.11)

**Laboratory:** CSA International

**Test Report(s):** Certificate 139949, dated March 15, 2006.

**Description:** Gas-fired commercial kettles as listed below. Unit is comprised of on-off switch, pilot light, transformer, thermostat and gas valve, gas burners and grounding terminals. They have a lift cover and either an enclosed base or open leg stand.

Model No.	Mfr's Specified Nominal Heating Input (Btu/hr)
KGT-6-T	36,000
KGT-12-T	53,000
KGL-25-T	90,000
KGL-40-(T)(SH), (HA)-MKGL-40-(T)	140,000
KGL-60(80)(100)-(T)(SH) (HA)-MKGL-60(80)(100)-(T)	190,000

**Terms and Conditions:** The above gas-fired commercial kettles are accepted under the following conditions:

1. Units shall use natural gas only.
2. Units may be installed on combustible flooring. Clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.
3. Units shall be installed in accordance with manufacturer's instructions and RS 15-1 (ANSI Z223.1 - the National Fuel Gas Code) requirements.
4. The installation shall not interfere with combustion air, accessibility for operation and servicing.
5. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
6. Special precautions regarding fans in the vicinity of the equipment may be required to prevent interference with operation of the equipment.
7. For grease removal, suitable baffle type grease filters, MEA-accepted, shall be installed.
8. Gas line tubing and fitting connector shall permit flexibility for operation, cleaning and servicing, and shall be MEA-accepted for such use.
9. All gas line connections shall be made and equipment gas input settings shall be set by the licensed plumber installing unit.
10. All work provided by the installer from the point of gas utility company main line service termination to the equipment shall be subject to approval by the plumbing inspector.
11. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
12. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
13. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance Oct. 11, 07

Examined By [Signature]