



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 146-08-M

**Manufacturer:** RJF International Corporation  
3875 Embassy Parkway  
Fairlawn, OH 44333

**Trade Name(s):** Revolve & Accord

**Product:** Non-woven wall covering substrate material for digital printing  
MEA Index #440-320 – Interior Finish

**Pertinent Code Section(s):** 27-348

**Prescribed Test(s):** RS 5-5 (ASTM E84), Toxicity

**Laboratory:** Southwest Research Institute (SwRI) – Test: ASTM E84  
Anderson Laboratories (AL) – Test: Toxicity

**Test Report(s):** SwRI Project No: 01.13536.01.147, dated 3/31/2008.  
AL Test No. 675, Sample V-443, dated 1/7/2008.

**Description:** Non-woven, grounds-coated wall covering with recycle content to be used for digital printing by **Revolve**.

Non-woven, grounds-coated, gravure-printed wall covering with recycle content by **Accord**.

Flame Spread Rating: 20  
Smoke Developed Rating: 15

**Terms and Conditions:** The above-described wall covering materials, as having interior finish Class 'A' with flame spread rating as indicated above, are accepted under the following conditions:

1. Upon exposure to fire, the materials **do not** produce products of decomposition or combustion that are more toxic than those given off by wood or paper when decomposing or burning under comparable conditions.
2. All shipments and deliveries of such materials shall be provided with label, suitably placed, certifying that the materials shipped or delivered are equivalent to those tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance May 14, 2008

Examined By Simon Derfshidan