



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 149-08-E

**Manufacturer:** HearthStone Quality Home Heating Products  
317 Stafford Avenue, Morrisville, VT 05680

**Trade Name(s):** HearthStone

**Product:** Gas-fired room heating appliance  
MEA Index 410-70 – Heaters

**Pertinent Code Section(s):** Subchapter 14, RS 14-2

**Prescribed Test(s):** RS 14-6 (ANSI Z21.88-2005)

**Laboratory:** Intertek Testing Services

**Test Report(s):** Bari (Model #8180), Report No. 3109401-T1  
issued October 23, 2007.  
Luno (Model #8160), Report No 3109399-T1  
issued January 17, 2008.  
Report No. 3109399MID-001 issued April 9, 2008.

**Description:** Gas-fired room heaters designed with sealed fireboxes and large glass viewing areas to enhance room ambiance and o provide supplemental heating.

### Product Covered

Model No.	Minimum Input Rating (Btu/hr)	Maximum Input Rating (Btu/hr)
<b>Bari (8180)</b>	<b>26,500</b>	<b>26,500</b>
<b>Luno (8160)</b>	<b>26,500</b>	<b>26,500</b>
<b>Modena (8140)</b>	<b>26,500</b>	<b>26,500</b>

**Terms and Conditions:** The above-described gas-fired vented appliances are accepted for decorative heating under the following conditions:

1. Units shall be fired with natural gas only.
2. Units are for indoor installation only with combustible air and required ventilation air provided.
3. Venting of the equipment is subject to Section 27-879 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance June 5, 2008  
Examined By Donald [Signature]