

## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 152-07-E

Manufacturer: York International-Unitary Products Group,

P.O. Box 19014, Wichita, KS 67204-9014

Trade Name(s): York

**Product:** Outdoor condensing units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11A (UL 1995)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** SA3483, Volume 3, dated September 13, 2005.

**Description:** The York 13 SEER condensing units are the outdoor parts of a versatile system of air conditioning. They are designed to be custom-matched with those of UPG's complete line of evaporator sections, each designed to serve a specific function. Units, with model numbers and cooling capacities, are listed below:

Model No.	Mfg's. Specified Nominal Cooling Capacity (Tons)
AM012MA32#*	1.0
AM018MA32#*	1.5
AM024MA32#*	2.0
AM030MA32#*	2.5
AY012MA32#*	1.0
AY018MA32#*	1.5
AY024MA32#*	2.0
AY030MA32#*	2.5

Note: # - indicates the Product Generation (1=1st, 2=2nd, etc.)

<sup>\* -</sup> indicates the Style Letter or Revision Level (alpha-suffix letter)

**Terms and Conditions:** The above-described condensing units are accepted for under the following conditions:

- 1. Units are for outdoor installation only.
- 2. Units shall use only Refrigerant R-22.
- 3. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
- 4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
- 5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
- All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance \_\_\_\_

Examined By