



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 154-07-E

Manufacturer: Liebert Corporation, 1050 Dearborn Drive, Columbus, Ohio 43229

Trade Name(s): Liebert DS Air Conditioner

Product: Special purpose air conditioners

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11A (UL 1995)

Laboratory: Canadian Standards Association (CSA)

Test Report(s): CSA Report No. 1633124, dated May 22, 2007.

Description: Special purpose, permanently-connected air conditioning units with down flow or up flow air discharge designed for computer or electronic equipment rooms, or general purpose rooms. Units utilize a compressorized system with remote- or self-contained heat rejection and various refrigerants or may use fan coil evaporators or fan coil chilled-water or water-glycol mixture with remote heat rejection. Units may be factory- or field-charged. These units may also be equipped with electric, steam, gas or hot water reheat and/or electric or steam humidifiers, and/or factory- or field-installed condensate pumps. Units, with model numbers and cooling capacities, are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity (Tons)
DS/VS028*	8
DS/VS035*	10
DS/VS042*	12
DS/VS053*	15
DS/VS070*	20
DS/VS077*	22
DS/VS105*	30

*-Model number may have variable prefix and/or suffix digits

Terms and Conditions: The above-described air conditioner units are accepted under the following conditions:

1. Units shall utilize R-22 or R-407C refrigerants only.
2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 8/31/07
Examined By [Signature]