



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 16-08-E

Manufacturer: Wolf Steel Ltd.
24 Napoleon Road
Barrie, Ontario L4M 4Y8
CANADA

Trade Name(s): Napoleon & Continental Fireplaces

Product: Factory-built wood burning fireplaces/Room heaters
MEA Index #300-10 – Fire Place

Pertinent Code Section(s): Subchapter 14

Prescribed Test(s): RS 14-21 (UL 1482) RS 14-19 (UL 127)

Laboratory: Intertek Testing Services NA, Inc.

Test Report(s): Report #3099267 issued November 20, 2007
Report #3098605TOR-004 issued November 19, 2007.

Description: Freestanding, wood-burning units intended to give supplemental heating for space.

Model No.	Type	Input (Btu/hr)	Output (Btu/hr)
NPS40	Pellet Room Heater	N/A	8,000 – 43,000
NZ-26	Solid Fuel Fireplace	N/A	70,000
NZ-26WI	Solid Fuel Fireplace	N/A	70,000
NPI40	Pellet Room Heater	N/A	8,000 – 43,000

Note: Minimum clearance from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Terms and Conditions: The above-described factory-built fireplaces are accepted for supplemental heating and decorative purposes under the following conditions:

1. Installation shall be in accordance with the listed laboratory's specifications, manufacturer's supplied instructions and Section 27-848 of the New York City Building Code. Furthermore, the units shall also be vented in accordance with Section 27-856 of the Building Code.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 9, 2008
Examined By Donald [Signature]