



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 172-07-M

Manufacturer: Mehler Texnologies GmbH, Edeltzeller Str. 44,
36043 Fulda, GERMANY

Trade Name(s): Valmex

Product: PVC-coated fabric for flex sign

Pertinent Code Section(s): 27-499, 27-501, 27-507 and TPPN #11/99

Prescribed Test(s): RS 7-3 (NFPA 701 Test Method 2)

Laboratory: Diversified

Test Report(s): Diversified test report # 5467, dated October 3,
2005

Description: Flame-retardant vinyl polyester fabric, Valmex 7520 Mesh Plus FR, is a flex sign material. The material has an acrylic coated front and back. The product is used in the print industry for banners, signs and billboards.

Terms and Conditions: The above material is accepted as meeting the flame resistance requirements of Sections 27-506 and 27-507 of the New York City Building Code for use as flex signs, with the following conditions:

1. The acceptance of this material is limited to flame resistance only.
2. Structural and other requirement shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99.

3. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Sections 27-499 and 27-501, and the New York City Zoning Resolution.
4. All shipments and deliveries of such materials shall be provided with a label, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance June 13, 2007

Examined By Simon Derkhitans