



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 175-05-E

Manufacturer: Lochinvar Corporation, 300 Maddox Simpson Parkway, Lebanon, Tennessee 37090.

Trade Name(s): Lochinvar, Power-Fin.

Product: Gas fired hot water boiler.

Pertinent Code Section(s): 27-800, 27-824, RS 14-2 (ANSI Z223.1).

Prescribed Test(s): RS 14-6 (ANSI Z21.13)

Laboratory: CSA International

Test Report(s): CSA 189136-1566305 dated July 30, 2004.

Description – Gas fired water boiler, CBN Series, designed for indoor installation only. Unit comprises heat exchanger, stainless steel main burner, a spark ignition system comprising flame sensor, igniter, ignition module and combination gas valves with built-in pressure regulator and ASME relief valve. Units are provided with hot water limit control with setting at 230 degrees, Fahrenheit, maximum. Units with model numbers and input heating rates are listed below:

Model No.	Input Heating Rate BTUH
CBN045	45,000
CBN075	75,000
CBN090	90,000
CBN135	135,000
CBN180	180,000
CBN215	210,000
CBN260	260,000
CBN315	315,000
CBN360	360,000
CBN399	399,000
CBN500	500,000

Notes: 1. Units are approved for installation on combustible flooring. Minimum clearances from combustible construction shall be follows: top – 14 inches (45-180) 29 inches (315-500), front – alcove (24 inches suggested for service), flue – 1 inch in all directions, left side – 18 inches(24 inches suggested for service), right side – 6, back – 6 inches.

Terms and Conditions: That the above described gas fired hot water boilers, constructed in accordance with the ASME Code and installed as per clearances to combustible construction specified above, be accepted for use wit natural gas only, when connected to compatible approved gas vent in accordance with Article 15 of Building Code. This acceptance in no way includes the external piping, connections, and appurtenances thereto, which are required to fully conform with applicable provisions of law, but have been tested in conjunction with this application. Approval If all electrical equipment, apparatus, materials and devices shall be obtained from the Department before installation. All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance February 22, 2006
Examined by Simon Derphudan