



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 20-06-E

Manufacturer: TRANE, 4811 South Zero Street, Fort Smith, AR 72903

Trade Name(s): Trane or American Standard

Product: Self-contained cooling units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1); RS 13-11B (UL 1995), RS 14-6 (ANSI Z21.47)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File SA11679, dated January 9, 2006

Description: Self-contained air-conditioning units. R-410A refrigerant is used for the system. Cooling section is comprised of hermetically sealed compressor, air-cooled condenser, evaporator coil with direct-drive blower, expansion valve and safety controls. Units, with model numbers and cooling capacities, are listed below:

Model No.	Cooling Capacity (BTUH)
4TCC3018A1000A	18000
4TCC3024A1000A	23000
4TCC3030A1000A	28000
4TCC3036A1000A	35000
4TCC3036A3000A	35000
4TCC3036A4000A	35000
4TCC3042A1000A	40000
4TCC3048A1000A	46500
4TCC3048A3000A	46500
4TCC3048A4075A	46500
4TCC3060A1000A	58000
4TCC3060A3000A	58000
4TCC3060A4000A	58000

Terms and Conditions: The above-described packaged air-conditioning units are accepted under the following conditions:

1. Units shall be installed outdoors only.
2. Units shall use only Refrigerant R-410A.
3. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 3/12 / 07

Examined By 