



NYC Department of Buildings  
 280 Broadway, New York, NY 10007  
 Patricia Lancaster, FAIA, Commissioner  
 (212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 205-06-E

**Manufacturer:** International Comfort Products, 7310 West Morris Street, Indianapolis, Indiana 46231

**Trade Name(s):** Heil, Comfortmaker, Airquest, Arcoaire, ICP Commercial, KeepRight, Tempstar, Kenmore

**Product:** Heat pump condensing sections

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-11B (ANSI B9.1), RS 13-13 (UL 1995)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File SA11583, dated December 2, 2005

**Description:** Heat pump 13 SEER condensing sections designed for outdoor installation. R-410A is the refrigerant used for the system. Unit is comprised of a scroll compressor, air-cooled condenser with fan, electrically-operated reversing valve and safety controls. Units, with model numbers, heating and cooling capacities, are listed below:

Model No.	Mfr.'s Specified Cooling Capacity (BTUH)	Mfr.'s Specified Heating Capacity Range (BTUH)
(C, H, T) 4H318**A	17,400	10,800- 18,000
(C, H, T) 4H324**A	23,000	15,100- 24,000
(C, H, T) 4H330**A	30,000	21,000- 30,000
(C, H, T) 4H336**A	36,000	24,400- 36,000
(C, H, T) 4H342**A	41,500	28,600- 42,000
(C, H, T) 4H348**A	47,000	31,000- 48,000
(C, H, T) 4H360**A	59,500	37,800- 60,000

\* A= Standard grill, G= Enhanced grill

\* H= 208/230 three phase, K= 280/230 single phase, L= 460 three phase

**Terms and Conditions:** The above-described heat pump air-cooled condensing units are accepted under the following conditions:

1. Units shall be installed outdoors.
2. Units shall use only Refrigerant R-410A.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
4. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance January 1, 2007

Examined By Siuis Derkshdam