



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 217-07-M

<b>Manufacturer:</b>	Les Portes Lambton/Lambton Doors 235 2 <sup>nd</sup> Avenue Lambton, Quebec, CANADA G0M 1H0
<b>Trade Name(s):</b>	Les Portes Lambton/Lambton Doors
<b>Product:</b>	Fire-rated door assemblies Index #290 – Fire Doors
<b>Pertinent Code Section(s):</b>	27-329, 27-342
<b>Prescribed Test(s):</b>	RS 5-6 (ASTM E152)
<b>Laboratory:</b>	Intertek Testing Services
<b>Test Report(s):</b>	3037822, 3041853, 3052813, 3052813(s), 3063900, 3064867(b), 3073514(a), 3073514(b), 3119216COQ-002

**Description:** 90-minute fire-rated doors (single-swing, pairs, double-egress) and wood frames (single-swing and pairs). Doors are of proprietary mineral core construction. Maximum size: 4'0" x 9'0" (single-swing), 8'0" x 9'0" (pairs) and 8'0" x 8'0" (double-egress). May include listed Firelite glazing, with proprietary glazing kit (Maximum exposed area of 2510 inches square), flush, panel or inlaid molding type.

**Terms and Conditions:** The above-described fire-rated doors and frames are accepted for Class "B" rating with the following conditions:

1. Doors shall be operated by an approved fusible link or other New York City-approved automatic closing mechanism.

2. Doors shall be installed in accordance with Laboratory limitation, manufacturer's instructions and Reference Standard RS 5-8 (NFPA 80) for Class B opening.
3. Certificates or labels accompanying all shipments shall be provided by the testing service which shall be regularly engaged by the manufacturer to make periodic inspections and/or tests of the doors in the course of their manufacture.
4. All shipments and deliveries of such materials shall, in addition, be accompanied by a metal tag certifying that the materials shipped or delivered are equivalent to those tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance February 6, 2008

Examined By Simon Deshpande