

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 224-03-M

Report of Material and Equipment Acceptance Division

Manufacturer – The Maiman Company, 3839 East Mustard Way, Springfield, Missouri 65803.

Trade Name – Thermal fused doors.

Product – Fire rated door assemblies.

Pertinent Code Sections – 27-329, 27-342.

Prescribed Test – RS 5-6 (ASTM E-152).

Laboratory – Intertek Testing Services.

Test Report – WHI-495-1456.

Description – 45, 60, and 90 minute mineral core fire doors with Neer Veneer® faces and 1mm thick PVC edgebands which are for use in fire rated door assemblies. These doors can be labeled with either a Warnock Hersey neutral pressure or positive pressure, Category “A” or Category “B”, fire label. Doors can be used in single swing or pair swing applications. Lite openings are permitted, but must be used with approved lite kits and fire rated glass. 60 and 90 minute doors with over 100 square inches of visible glass cannot bear a temperature rise rating on the label.

Recommendation - That the above described doors be accepted as having either a 45, 60, or 90 minute fire protection rating when installed in accordance with Reference Standard RS 5-8 (NFPA 80-1999) for Class B and C openings, on condition that the certificates or labels accompanying all shipments shall be provided by the testing service which shall be regulatory engaged by the manufacturer to make periodic inspections and/or tests of the frames in the course of their manufacture. All shipments and deliveries of such material shall, in addition, be accompanied by a metal tag certifying that the materials shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance Feb/27/04

Examined By S Derfida