

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code SECTION 27-131, the following equipment or material has been found for use in accordance with the report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner

MEA 226-05-M Report of Material and equipment
Acceptance Division

Manufacturer- USG Interiors, Inc. 125 S. Franklin Street, Chicago, IL. 60606-4678.
Trade Name(s) - ACOUSTONE Product Line, UL Type Designation AP, Sandrift,
Glacier, Frost.

Product-Acoustical Ceiling Panels and Tiles.

Pertinent Code Sections - 27-348. Prescribed

Tests - RS 5-5, (ASYM E84), Toxicity.

Laboratories - Underwriters Laboratories Inc.; Southwest Research Institute. Test
Reports - Southwest Research Institute REPORT 01.11020, UL letter report
R3623 98NK27400 dated 11-12-1998, UL letter report R3623 98NK27400
dated 12-2-1998.

Flame Spread Rating - 25

Smoke Developed Rating - 50

Recommendation - That the above described acoustical ceiling products be accepted for interior use finish, with Class A flame spread rating and smoke developed rating listed above. Upon exposure to fire, the acoustical panels did not produce products of decomposition that were more toxic than wood when decomposing or burning under comparable conditions.

All shipments and deliveries of such equipment shall be provided with a laboratory label and a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance July/28/05
Examined By S Deshpandam