



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 24-08-E

**Manufacturer:** LG Electronics USA Inc.  
Air Conditioners OBU  
76 Seongsan-Dong, Changwon-shi  
Kyongsangnam-do, 641-310, KOREA

**Trade Name(s):** LG Electronics

**Product:** Packaged Terminal Air Conditioners & Heat Pumps  
MEA #20-120 – Split-system Air Conditioning

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-6 (ANSI B9.1), RS 13-12 (UL 484)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL SA13362 issued March 17, 2006 and revised June 19, 2008.

**Description:** Packaged terminal air conditioners and heat pumps, Series LP, as tabulated below. All units employ a slid-out-type chassis.

Model Type	Model Number	Unit Type (Indoor/Outdoor/Both)	Cooling Capacity (Btu/hr) (Cooling / Heating)
Packaged Terminal Air Conditioners	LP070CED-Y8	Single Unit	7,600 / 7,400
	LP090CED-Y8		9,000 / 8,800
	LP120CED-Y8		11,800 / 11,500
	LP150CED-Y8		14,300 / 14,100
Packaged Terminal Heat Pumps	LP070HED-Y8	Single Unit	7,600 / 7,400
	LP090HED-Y8		9,000 / 8,800
	LP120HED-Y8		12,000 / 11,800
	LP150HED-Y8		14,300 / 14,100

**Permanent connected units (265V)**

<b>Model Type</b>	<b>Model Number</b>	<b>Unit Type (Indoor/Outdoor/Both)</b>	<b>Cooling Capacity (Btu/hr) (Cooling / Heating)</b>
<b>Packaged Terminal Air Conditioner</b>	<b>LP155CED1</b>	<b>Single Unit</b>	<b>14,000</b>
<b>Packaged Terminal Heat Pump</b>	<b>LP155HED1</b>	<b>Single Unit</b>	<b>14,400</b>

**Terms and Conditions:** The above described Reverse cycle cooling –heating units be accepted when utilizing the refrigerant R-22 under the following conditions:

1. All equipment shall be furnished with a permanently fixed metal tag stating that if installed in New York City, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Building before installation.
3. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance July 17, 2008

Examined By Sam Derkholam