



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 25-06-E

Manufacturer: Progressive Manufacturing 20 Air Park Road
West Lebanon, NH 03784

Trade Name(s): Gas Stone with Fusion Basket

Product: Gas-fired decorative log appliance

Pertinent Code Section(s): 27-800

Prescribed Test(s): RS 14-6 (ANSI Z 21.60a)

Laboratory: Omni Test Laboratories

Test Report(s): 284-L-05-5, dated November 22, 2004

Description: Gas-fired decorative log appliance designed to provide supplemental heating and to enhance the esthetics of a room. The stones are ceramic and are designed to be used in vented fireplace. The model numbers and their input BTU ratings are also listed as follows:

Model No.	Rating (BTU/Hr)
Vision Fin Basket #VFB-01	Maximum Input 45,000
Gas Stones (Gas Logs)	9.38 KW High Fire

Terms and Conditions: The above-described gas-fired log appliance is accepted for decorative heating operation on the following conditions:

1. To be installed in vented fireplaces only.
2. Clearance to combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.
3. Heating operation on natural gas and for indoor installation only with combustion air and required ventilation air provided. Venting of fireplace is subject to Section 27-879 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and delivery of such equipment shall be accompanied by a metal tag permanently affixed to the units and suitably placed, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the New York City Building Code.

Final Acceptance 4/7/2006
Examined by Stephen M. Jansen