



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 26-95-E Vol. 2

Manufacturer: National Refrigeration & A/C Prod., Inc.
539 Dunksferry Road, Bensalem, PA 19020

Trade Name(s): Trenton Refrigeration

Product: Air- and water-cooled condensing units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-6 (ANSI B9.1), RS 14-6 (UL 1995)

Laboratory: Intertek Services

Test Report(s): Report No. 3076220-004 dated May 23, 2005,
revised January 3, 2007.

Description: Air- and water-cooled condensing units with 1/5, 1/4, 1/3, and 1/2 Hp. The units come in a variety of refrigerant types ranging from R-134A, R-22, R-12, R-404A and R-502. Units operate on 115V, single phase, 60Hz.

Product Covered

Units can also be trade-named Trenton Refrigeration, **Models: T fb H, M, L fb 1, 2, 3, 4, 5 fb 0020, 0024, 0025, 0026, 0033, 0050.**

OR

Models: A fb H, M, L fb R, C fb 1, 2, 3, 4, 5 fb 0020, 0024, 0025, 0026, 0033, 0050.

Terms and Conditions: The above-described condensing units are accepted for outdoor or indoor installation under the following conditions:

1. Units may use Refrigerants R-134A, R-22, R-12, R-404A and R-502.
2. All equipment shall be furnished with permanently-affixed metal tags stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 11/21/07
Examined By Stephen. [Signature]