



NYC Department of Buildings  
 280 Broadway, New York, NY 10007  
 Patricia Lancaster, FAIA, Commissioner  
 (212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 264-06-E

**Manufacturer:** International Comfort Products, 7310 West Morris Street, Indianapolis, Indiana 46231

**Trade Name(s):** Heil, Comfortmaker, Airquest, Arcoaire, ICP Commercial, KeepRight, Tempstar, Kenmore

**Product:** Fan coil units

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-11B (ANSI B9.1), RS 13-11 (UL 207, UL1995)

**Laboratory:** Underwriters Laboratories, Inc

**Test Report(s):** UL File SA11583, dated April 20, 2005

**Description:** Multi-poise fan coil units using R-410A as the refrigerant. Units consist of evaporator coils and fans, blower motors, capillary tubing and controls. Units, with model numbers and cooling capacities, are listed below.

Model Number	Mfr's Specified Nominal Cooling Capacity, Tons
FSM4X18***	1.5
FSM4X24***	2
FSM4X30***	2.5
FSM4X36***	3
FSM4X42***	3.5
FSM4X48***	4
FSM4X60***	5

\* Denotes voltage, cabinet size, heating size, and variations

**Terms and Conditions:** The above-described fan coil units are accepted under the following conditions:

1. Units shall use only Refrigerant R-410A.
2. If utilized for residence heating, air circulation system shall have (a) one register or grille without closable shutters and the duct leading thereto shall be without a damper, or (b) dampers and shutters within the system that shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance March 29, 2007

Examined By Siun Derphudam