



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 282-06-E

Manufacturer: Rheem Manufacturing Company

Trade Name(s): Rheem

Product: Outdoor air-cooled condensers and Compressor Units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-6 (ANSI B9.1), RS 13-11 (CSA C22.2 No. 236; UL 1995)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): No. SA7930, Dated January 30, 2004

Description – Outdoor air-cooled condensing and compressor unit used for refrigeration and air conditioning systems. This is a component comprising of condenser coil, fan motor and appropriate controls. Units, with cooling capacities are listed below:

Model No.	MFr's Specified Nominal Cooling Capacity TONS
RAMC-018*	1.5
RAMC-024*	2.0
RAMC-030*	2.5
RAMC-036*	3.0
RAMC-042*	3.5
RAMC-048*	4.0
RAMC-060*	5.0

NOTE – * Model designation may be suffixed.

Terms and Conditions – That the above outdoor air-cooled condensers be accepted under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation

Final Acceptance 7/3/06

Examined by Shyam R. Das

