



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 29-07-M

Manufacturer: Lafarge, P.O. Box 3, Route 9-W
Ravena, N.Y. 12143

Trade Name(s): Ravena Type I/II Portland Cement

Product: Cement for use in concrete, mortar and non-specialty
grout.
MEA Index #120-10 – Cement Portland

Pertinent Code Section(s): 27-603, Reference Standard RS 10

Prescribed Test(s): RS 10-3 (ASTM C150) and AASHTO M-85

Laboratory: Independent Testing Laboratories, Inc. (ITL)

Test Report(s): ITL Reports dated March 14, 2007.

Description: Ravena Type I/II Portland cement is a finely-ground grey powder intended for general construction use and meets the requirement of ASTM C150 standard specification for Portland cement.

Terms and Conditions: The above-described materials are accepted as Type I and II Portland cement with the following conditions:

1. Preliminary mixes and construction operations shall be subject to controlled inspection as specified in Tables 10-1, 10-2 in Section 27-605 of the New York City Building Code.

2. All shipments and deliveries of Portland cement shall be provided with a mill certification report from the manufacturer, certifying that the cement shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 16, 2008

Examined By Simon D. ...