



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 299-91-E Vol.12

**Manufacturer:** Potter Electric Signal Co., 2081 Craig Road, St. Louis, MO 63146

**Trade Name(s):** Potter Electric Signal

**Product:** Pressure switches

**Pertinent Code Section(s):** Subchapter 17 and Reference Standard RS 17

**Prescribed Test(s):** UL 753, UL 346

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** S309, Project 76NK9591, issued February 3, 1977, revised January 18, 2006

**Description:** Models PS10, PS40, PS100 and PS120 are intended for use in dry- and wet-pipe systems to detect a change in pressure. Models with Suffix "A" may employ one or two switches.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated September 11, 2006, F.P. Index #0608051.

**Terms and Conditions:** The above units are accepted on condition that:

1. All uses, applications and installations comply with all applicable provisions of the New York City Building Code, specifically Subchapter 17, and Reference Standards 17-2, 17-2A, 17-2B and 17-3.
2. The installation and pressure settings shall be in accordance with the manufacturer's recommendation and UL Standard.
3. Manufacturer's maintenance procedures and UL listing requirements & limitations shall be complied with.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Note: In accordance with Section 27-131(d) of the New York City Building Code, all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance October 23, 2006  
Examined By Donald J. [Signature]