



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 3-02-E Vol.4

Manufacturer: System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name(s): Gamewell.

Product: Fire Alarm Equipment.

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR).

Test(s): UL 268.

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL multiple listing file S1195, issued April 11, 2004, revised May 5, 2004.

Description –

Gamewell Model No.	System Sensor Model No.	Description
SS-L	FSL-751	Smoke detector, addressable, intelligent laser photoelectric type

The SS-L is for use with any listed compatible base. The base/head combination is for use with an MEA approved Gamewell compatible control units. The amount of smoke observed by the detector is reported to the panel by varying the width of pulse 4, As smoke is encountered, the width of this pulse increases.

Installation – These devices are intended for installation on a vertical wall surface or the ceiling. These units may be installed in open areas with air velocities between 0-4000 fpm.

Terms and Conditions: That the above units are accepted on condition that all uses, configurations, arrangements, and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72, UL Standard and UL Listing. Periodic sensitivity tests where required shall be conducted in accordance with the regulations of Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 3, 2006

Examined By Donald J. Hoff