



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 30-07-E

Manufacturer: Lennox Industries Inc., 200 S. 12th Avenue, Marshalltown, IA 50158

Trade Name(s): Lennox

Product: Air conditioner units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11A (UL 1995)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): SA11694 dated April 7, 2006.

Description: Air conditioner units for residential use. Cooling section employs refrigerant R-22. Cooling section is comprised of hermetically sealed compressor, air-cooled condenser, evaporator coil with direct drive blower, expansion valve and safety controls. Units, with model numbers and cooling capacities, are listed below:

Model Designation (1)	Capacity Rating (Tons)
XC16 – 024 – 230 (#) – 01	2
4SCU16LT124P– 1	
W4GC624A	
XC16 – 036 – 230 (#) – 01, – 02	3
4SCU16LT136P– 1	
W4GC636A	
XC16 – 048 – 230 (#) – 01, – 02	4
4SCU16LT148P– 1	
W4GC648A	

Model Designation (1)	Capacity Rating (Tons)
XC16 – 060 – 230 (#) – 01, – 02	5
4SCU16LT160P– 1	
W4GC660A	

Notes:

(1) – Suitable for outdoor installation.

(#) – May be followed by C, G and/or T. Designates unit options as listed in Report: C=Canadian, G=Gov't. Options (adding high- and/or low-pressure switch), T=Technicoat (Coil coating, coastal applications).

Terms and Conditions: The above-described air conditioner units are accepted under the following conditions:

1. Units are for residential use.
2. Units shall use only Refrigerant R-22.
3. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 1/7/08

Examined By Sayon, R