CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner
MEA 301-00-M
Report of Material and Equipment Acceptance Division

Manufacturer - Safe Encasement System, 7860 Dana Point Court, Las Vegas, Nevada 89117.
Trade Name - Safe Encasement System.
Product - Penetrating stabilizer/protective skin for interior finish acceptance.
Pertinent Code Section(s) - 27-348.
Prescribed Test(s) - RS 5-5(ASTM E84), Toxicity.
Laboratory - Southwest Research Institute.
Test Report(s) - SwRI No. 01.03048.01.178 [1] dated April 5, 2000 and 01.03051.01.066 dated July 24, 2000.
Description - SE-110 penetration stabilizer, water-based primer sealer, is applied directly over interior finish surfaces and is overcoated with SE-120, protective skin, water-based top coat, to form an encasement system that seals the fiber release.

Flame Spread Rating - 10; Smoke Developed Rating - 15.

Recommendation - That the above material be accepted for interior finish usage, with Class A flame spread rating and smoke developed rating as indicated above on condition that all uses and application are in compliance with the New York City Building Code, the EPA rules and regulations, the manufacturer's instructions and the laboratory listing. Upon exposure to fire the material did not produce products of decomposition or combustion that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. All shipments and deliveries of such materials shall, in addition, be accompanied by a metal tag certifying that the materials shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance AUG 24 2000

Examined By S Dalkhudar