

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 306-03-M

Report of Material and Equipment Acceptance Division

Manufacturer – Owens Corning, One Owens Corning Parkway, Toledo, Ohio 43659.

Trade Name – Owens Corning, Select Sound Acoustic Blanket.

Product - Select sound acoustic blanket for interior finish acceptance.

Pertinent Code Section(s) - 27-348.

Prescribed Test(s) - RS 5-5 (ASTM E84), Toxicity.

Laboratories - Omega Point Laboratories Inc.; Anderson Laboratories Inc.

Test Report(s) - OPL No. 13060-115191 dated July 28, 2003 and ARL No. 596 dated June 17, 2003.

Description – SelectSound™ Black Acoustic Blanket is an all-black wool product with a black mat surface composed of inorganic glass fibers. It is excellent for eliminating light reflections while providing superior acoustical performance in multiplex theaters, sound studios and performing arts centers. It is also ideal for use above suspended metal ceiling systems.

Flame Spread Rating - 15;

Smoke Developed Index - 15.

Recommendation - That the above material be accepted for interior finish usage, with Class A flame spread rating and smoke developed rating as indicated above. Upon exposure to fire the material did not produce products of decomposition or combustible that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance DEC/30/03

Examined By S. Derphida