

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 318-03-E
Report of Material and Equipment Acceptance Division

Manufacturer – Electrolux Professional S.P.A., Viale Treviso 15 Pordenone, Italy 33170.

Trade Name(s) – Electrolux Professional S.P.A.

Product – Electric Bratt Pan.

Pertinent Code Section(s) -27-777, 27-787.

Prescribed Test(s) - RS 14-6 (UL 197).

Laboratory – Intertek Testing Services, NA Inc.

Test Report(s) – 30438062-30438069 dated July 3, 2003.

Description – Bratt pan is a cord connected unit for cooking. It is a freestanding unit. Unit comprises a cooking pan, on/off switch, energy regulator, thermostat with safety controls.

Products Covered:

Model	Electrolux P/N	Zanussi P/N
Half Module Electric Bratt Pan	168040	168840
Full Module Electric Bratt Pan	168041	168841

Model Similarity:

The Half Module Electric Bratt Pan is similar in design to the Full Module Electric Bratt Pan. The only difference between the two is the capacity and variances in electrical components.

The Electrolux and Zanussi Systems are electrically identical in design. The only difference between the two products lines are minor exterior modifications (rounded corners, and color of panels).

Electrical Ratings:

Electric Bratt Pan	Electrolux P/N	Zanussi P/N	Voltage	Current/Power	Frequency
Half Module	168040	168840	208 VAC, 3 ϕ	11.4.A/4.1 kW	50/60 Hz
Full Module	168041	168841	208 VAC, 3 ϕ	22.8 A/8.2 kW	50/60 Hz

Recommendation - That the above electric Bratt Pan, be accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for ventilation.
3. The installation shall not interfere with accessibility for operation and servicing.
4. All shipments and deliverers of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in section 27-131 of the Building Code.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 2/24/04
Examined by [Signature]