

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

**MEA 314-03-E  
Report of Material and Equipment Acceptance Division**

**Manufacturer – Electrolux Professional S.P.A., Viale Treviso 15 Pordenone, Italy 33170.**

**Trade Name(s) – Electrolux Professional S.P.A.**

**Product – Commercial Electric Induction.**

**Pertinent Code Section(s) -27-777, 27-787.**

**Prescribed Test(s) - RS 14-6 (UL 197).**

**Laboratory – Intertek Testing Services, NA Inc.**

**Test Report(s) – 30438064 dated July 30, 2003 and 30399944 dated April 14, 2003.**

**Description – These are electric induction for commercial use. Units comprises hot top plate, on/off switch, and safety controls. Units with their ratings are listed below:**

**Products Covered:**

**PR700 Series Commercial Electric Induction Cook Tops.**

<b>Model</b>	<b>Electrolux P/N</b>	<b>Zanussi P/N</b>
<b>Cook Top PR700 Half Module</b>	---	168233
<b>Cook Top PR700 Full Module</b>	---	168234

**Electrical Ratings:**

<b>Model</b>	<b>Electrolux P/N</b>	<b>Zanussi P/N</b>	<b>Voltage</b>	<b>Current/Power</b>	<b>Frequency</b>
<b>Half Module</b>	---	168233	<b>208 VAC, 1 <math>\phi</math></b>	<b>31 A/6.4 kW</b>	<b>50/60 Hz</b>
<b>Full Module</b>	---	168234	<b>208 VAC, 3 <math>\phi</math></b>	<b>36 A/12.8 kW</b>	<b>50/60 Hz</b>

Recommendation - That the above electric induction, be accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for ventilation.
3. The installation shall not interfere with accessibility for operation and servicing.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in section 27-131 of the Building Code.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 2/24/04  
Examined by Shyam S. Datta