



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 317-01-E Vol. VI

Manufacturer: Notifier, 12 Clintonville Road, Northford, CT 06472-1001.

Trade Name(s): Ansul, Inc.

Product: Fire Alarm Equipment.

Pertinent Code Section(s): 27-968 through 27-977, Reference Standard RS 17-5 NFPA/NfiPA/No. 72.

Test(s): RS 17-5 ANSI/NiPA No. 72; UL 864.

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL Multiple Listing Files: S4935, issued June 16, 2005; S4923, issued June 16, 2005; S3623, issued June 10, 2005; S4935, issued June 16, 2005; S4935, issued June 16, 2005.

Description – The Ansul, Inc. Model Autopulse IQ-636X fire alarm control panel is multiple listed with Notifier’s Model NFS-640 (317-01-E). It also has releasing capability and uses the same optional equipment as the NFS-640 including compatible MEA listed manual pull stations, detectors, and modules.

Ansul, Inc.	Notifier
Autopulse IQ-636X FACP	NFS-640
IQ636-CPU Board	CPU-640
Ansul-NCA Network Control Annunciator	NCA
Ansul-DR-A4(+)/-B4(+)/-C4(+)/-D4(+)	Same w/o Ansul
Ansul-ABF-4(+), Ansul-ABS-2D(+)/-4D(+)	Same w/o Ansul
Note: (+) may include R suffix (Color Red) or B suffix *color Black)	Same w/o Ansul

Terms and Conditions: That the above units are accepted on condition that all uses, locations and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and with the Reference Standard 17-3 through RS 17-5, inclusive as applicable including the NFPA as appropriate, the UL listing, manufacturer's instructions , the Fire Department Directives, and with the Electrical Code of the City of New York, and on further condition that:

1. When used as a central office control communicator or a transmitter, the installation and operation of the equipment and devices listed herein shall comply with 3-RCNY §17-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler waterflow alarm, supervisory signal indications, and trouble indications.
2. Prior to the installation of the pre-recorded automatic evacuation system, a specific approval for a specific installation must be obtained from the Fire Department.
3. The connection of security/burglar devices and equipment to a fire command station is prohibited. A sign must be provided to indicate the same.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance November 22, 2005.
Examined by Donald J. [Signature]