



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 318-05-E

Manufacturer: Multistack Inc., 365 South Oak Street, West Salem, WI 54669.

Trade Name(s): Airstack.

Product: Modular Liquid Chillers.

Pertinent Code Section(s): 27-770, 27-777, RS 13-6 (ANSI B9.1).

Prescribed Test(s): RS 13-11 (UL 1995).

Laboratory: Intertek ETL SEMKO.

Test Report(s): No. 3078124-002, dated August 3, 2005.

Description – Modular air-cooled packaged chillers (Model ASP30), designed for indoor ducted, or outdoor installation The refrigerant used with either be R-22 or R-407C. Unit comprised of scroll compressors, brazed stainless steel type water evaporator, air to air condenser coil, condenser fan motors, expansion valves, receivers, and related safety controls. Safety control components include temperature control, low pressure control, and pressure limiting control. Units, with model number and cooling capacities are listed below:

Model No.	Nominal Cooling Capacity (Tons)
ASP30A	Two independent 14.7 Ton Circuits per Module

Terms and Conditions: That the above described modular air cooled packaged chiller, be accepted for indoor installation only, when utilizing Refrigerant R-22 or R-407C, under the following conditions:

1. Cooling tower or other compatible outdoor heat rejection equipment, if installed within 100 feet of any dwelling unit window, complies with all provisions of Section 27-770, Subdivision 4, and to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance *[Signature]*
Examined by 11/7/05