

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 319-03-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, 3825 Ohio Avenue, St. Charles, Illinois 60174.

Trade Name – System Sensor.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Test – UL 864.

Laboratory – Underwriters Laboratories, Inc.

Test Reports – UL file S3705 Project 96NK2538 and 03NK27394 (UL letter dated September 4, 2003), issued April 1, 1996 and revised May 28, 2003.

Description – EOLR-1 end-of-line supervision relay is intended to be used with separately listed compatible control units, for indoor use only

Model No.	Description
EOLR-1	End-of-the-line Supervision Relay

Pursuant to “Promulgation of the Rules relating to Materials and Equipment Application Procedures” dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated September 26, 2003, F.P. Index #0309029.

Recommendation- That the above equipment be accepted provided at all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation and spacing shall be in accordance with the manufacturer’s recommendation, NFPA 72 and the UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

Examined by

February 10, 2004
Donald J. [Signature]