



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 324-93-M Vol. 2

Manufacturer: Flomatic Corporation, 15 Pruyn's Island Drive, Glens Falls, N.Y. 12801

Trade Name(s): Flomatic Corp.

Product: Reduced-pressure-principle backflow prevention assemblies

Pertinent Code Section(s): P107.13 and P107.18 of Reference Standard RS-16

Prescribed Test(s): RS-16 (ASSE No. 1013)

Laboratory: University of Southern California, Foundation for Cross-Connection Control and Hydraulic Research

Test Report(s): Report Nos. 94-054 dated August 15, 1994, 94-055 dated August 16, 1994, 96-026 dated October 30, 1996, 2000-005 dated February 2, 2000, and 2001-008 dated March 24, 2001

Description: Reduced-pressure-principle type backflow prevention assemblies, Model series RPZ, designed to prevent the reverse flow of pollutants into the potable water supply. Assemblies are available in sizes of 2½", 3", 4", 6" and 8". Units are suitable for operation at 175 psi (maximum) and 180°F (maximum).

Terms and Conditions: The above-described backflow prevention assemblies are accepted under the following conditions:

1. Installation shall be in accordance with Reference Standard RS-16.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 1, 2007

Examined By Sivan Deshpande