

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found to be acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 326-03-M

Report of Material and Equipment Acceptance Division

Manufacturer – Prodema, S.A., B San Miguel, 20250 Legoreta Gipuzkoa, Spain.

Trade Name – HPC M1.

Product – Prefinished interior wood panel.

Pertinent Code Section - 27-348.

Prescribed Test - RS 5-5 (ASTM E-84), Toxicity.

Laboratory – VTEC Laboratories Inc.

Test Reports – V100-1771-21 dated July 17, 2003, VTEC #100-1771-37 dated July 21, 2003, and VTEC letter dated January 15, 2004.

Description – Prefinished interior wood panel – panels made of high-pressure laminate core faced with a natural wood veneer protected by a patented protective coating. The nominal thickness is 0.301 inch and a density of 2.29 psf.

Flame Spread and Smoke Rating:

Flame Spread – 10; Smoke developed – 45.

Recommendation - That the above described panel be accepted for interior finish usage, with Class A Flame Spread Rating and Smoke Developed Rating as indicated above. Upon exposure to fire the material did not produce products of decomposition or combustion that were more toxic than those given off by wood or paper when decomposing or burner under comparable conditions. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials are equivalent to those tested and acceptable for use, as provided for in Article 27-131 of the Building Code.

Final Acceptance Feb/27/04

Examined By S Derphida