

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 331-03-E
Report of Material and Equipment Acceptance Division

Manufacturer – AAON, Inc., 2425 South Yukon, Tusca, OK 74102.

Trade Name(s) –AAON Inc.

Product – Air cooling condensing units.

Pertinent Code Section – 27-770, 27-777.

Prescribed Test(s) - RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995).

Laboratory – Intertek Testing Services.

Test Report(s) – No. 3039659-003, dated October 7, 2003.

Description – Air cooled condensing units, CL Series designed for outdoor installation. R-22 is the refrigerant used for the system. Unit consists of hermetic sealed compressor, air cooled condenser coil with fan, and safety controls. Units, with model numbers and nominal cooling capacities, are listed below:

Model No.	Mfr.'s Specific Nominal Cooling Capacity Tons
CL-45	45
CL-50	50
CL-60	60
CL-70	70
CL-75	75
CL-95	95
CL-100	100
CL-110	110
CL-125	125
CL-134	134
CL-135	135
CL-155	155
CL-170	170
CL-190	190
CL-210	210
CL-230	230

Recommendation - That the above described air cooled condensing units, be accepted for outdoor when utilizing Refrigerant R-22 or HCFC-22, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be provisions with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliverers of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance

12/26/03

Examined by

Stephen M. Probst