

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner  
MEA 342-03-E

Report of Material and Equipment Acceptance Division

Manufacturer – Lenox Hearth Products, 1110 Nest Taft Avenue, Orange, CA 92865.

Trade Name(s) – Lenox Hearth.

Product - Gas fired vented decorative fireplace appliance.

Pertinent Code Section(s) -27-800, RS 14-2 (ANSI Z223).

Prescribed Test(s) - RS 14-6 (ANSI Z21.50, Z21.88a, Z21.11, Z21.44).

Laboratory – OMNI-Test Laboratories Inc.

Test Report(s) – Certificate No. 116-F-05-5 dated March 2, 2000.

Description – Gas fired decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room.

Model No.	Max Input BTUH	Minimum Input BTUH
EDVST	39,000	31,000
EDVPF	39,000	31,000
EDVCR	39,000	31,000
EDV3530	27,000	21,000
EDV4035	30,000	23,000
EDV4540	33,000	20,000

Recommendation - That the above described gas-fired vented appliances, be accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided.

Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 12/26/03

Examined By Shyam M. Jaiswal