

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 373-02-E

Report of Material and Equipment Acceptance Division

Manufacturer- Criosbanc S.P.A., Torregua, Italy for Scatena York Company, 2000
Oakdale Avenue, San Francisco, *CA 94124.*

Trade Name - Criosbanc.

Product - Refrigerated display cases- remote systems.

Pertinent Code Section(s)-27-771, 27-772, 27-777(f).

Prescribed Tests - RS 14-6 (UL 471).

Laboratory - Intertek Testing Services N.A.

Test Reports - No. 20332041, dated March 14, 2001, revised January 4, 2003. No. 46346 dated February 1, 1985, revised June 7, 1999.

Description - Approved models: Urania, Urania DVA (DV), Orione, Hermes, Gemini MZ (CV) Gemini MZS (DV), Gemini GC (CS), Gemini GCS (DS), Harmonia Series, and Athena. Forma, Diade, Sintesi, Elios C/D, Pegasus PG, Pegasus PD, and Discovery II/Samos - Versions SH1774, SH1763, SH1600, SH1424, SH1413, SH1250, and SH910. Climax III (Elios C/D), Pegasus (Pegasus PG/PD), Glycos, Discovery II/Samos, LaRotonda, Cronos and Retrobanco.

R-12, R-22, R-502, R-134a, or R-404a are the refrigerants used for the system.

Recommendation - That the above commercial refrigerated display cases be accepted, under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for ventilation.
3. The installation shall not interfere with accessibility for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.
6. All shipments and deliveries of such equipment shall be accompanied by a metal tag, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

Examined by

7-26-05

Shyan M. Basu