



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 375-07-E

Manufacturer: Selkirk Canada Corp., 375 Green Road, Stoney Creek, Ontario L8E 4A5, CANADA

Trade Name(s): SuperPro / SuperVent

Product: Factory-built insulated chimney sections/assemblies, for residential and building heating appliances

Pertinent Code Section(s): 27-855

Prescribed Test(s): RS 15-11 (ANSI / UL103)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File MH12531, dated March 30, 1983.

Description: This factory-built chimney is comprised of numerous components which may be installed together in modular fashion to achieve a variety of installation configurations. This product is intended for venting gas, liquid and solid fuel-fired residential type appliances and building heating appliances in which the maximum continuous flue-gas outlet temperatures do not exceed 1000°F.

The chimney consists of an inner stainless steel liner with an outer stainless steel pipe. The 1 inch space between the two pipes is insulated. The chimney is for single and multi-story buildings. The minimum installation clearance is 2 inches to enclosure walls and roof structure and the maximum height is 50 feet above the decorator base support.

Product Covered

Chimney, residential type and building heating appliance, Model "SC" or "SPR", Type HT, sizes 5, 6, 7 and 8 inches, ID chimney and chimney parts.

Terms and Conditions: The above-described factory-built chimneys are accepted for use, where allowed by the New York City Building Code, under the following conditions:

1. Chimneys shall not be enclosed with combustible materials.
2. Chimneys are intended for the venting of liquid or gas fuel exhaust gases at a temperature not exceeding 1000°F under continuous operating conditions in accordance with Reference Standard RS 15-11 of the New York City Building Code.
3. Chimneys shall be identified as "1000°F Chimney Part" and installed in accordance with all provisions of New York City Building Code, specifically Subchapter 15, Sections 27-855, 27864 and 27-869.01 for Listed Factory-built Chimneys.
4. All interior factory-built chimneys shall be enclosed in accordance with the Building Code.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 1/7/08

Examined By Shyam A