



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 377-07-E

Manufacturer: Lennox Hearth Products
1110 West Taft Avenue
Orange, CA 92865

Trade Name(s): Lennox, Merit Plus

Product: Gas-fired, direct vent decorative fireplace
MEA Index #300 – Fire Place

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223)

Prescribed Test(s): RS 14-6 (ANSI Z21.88)

Laboratory: Omni-Test Laboratories

Test Report(s): Certificate No. 116-F-47-5, dated September 5, 2007.

Description: Gas-fired, direct vent decorative fireplace designed to provide supplemental heating and to enhance the aesthetics of a room. Units shall operate on natural gas and for indoor installation.

Product Covered:

Model No.	Minimum Input Rate	Maximum Input Rate
MPLDV-30NM, MPLDV-30NE	10,500	13,000
MPLDV-35NM, MPLDV-35NE	13,000	17,000
MPLDV-40NM, MPLDV-40NE	19,500	25,000
MPLDV-45NM, MPLDV-45NE	20,000	26,000

Terms and Conditions: The above-described gas-fired vented appliances are accepted for decorative heating under the following conditions:

1. Units shall be fired with natural gas only.
2. Units are for indoor installation only with combustible air and required ventilation air provided.
3. Venting of the equipment is subject to Section 27-879 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 2/13/08

Examined By Steve M. Quinn