



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 386-02-E Vol. 2

**Manufacturer:** System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174

**Trade Name(s):** Silent Knight

**Product:** Fire alarm equipment

**Pertinent Code Section(s):** Subchapter 17 and Reference Standard RS 17

**Prescribed Test(s):** UL 864

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** Multiple Listing File S3511 issued March 31, 2006, revised August 10, 2006

**Description:** Fire alarm equipment.

<b>Notifier Model No.</b>	<b>Silent Knight Model No.</b>	<b>Description</b>
XP6-R	IDP-Relay-6	Relay Module
XP6-MA	IDP-Zone-6	Six-zone interface module
XP6-C	IDP-Control-6	Supervising control module
XP10-M	IDP-Monitor-10	Input monitor module

**Terms and Conditions:** The above fire alarm equipment is accepted on condition that:

1. All uses, locations and installations shall comply with Article 17, and Reference Standard RS 17-3 of the New York City Building Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives and the manufacturer's instructions.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance April 9, 2007.  
Examined By Donald [Signature]