



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 39-07-E

**Manufacturer:** ARNEG LLC, 4243 Lonat Drive, Nazareth, PA 18064

**Trade Name(s):** ARNEG LLC

**Product:** Commercial hot food cases

**Pertinent Code Section(s):** 27-777, 27-787

**Prescribed Test(s):** RS 14-6 (UL 197)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File E185568 dated April 9, 1997, revised September 19, 2000

**Description:** The units are heated merchandisers for use in commercial establishments. They are designed to display and hold food products at the proper temperatures and are equipped with water wells for humidity control.

Product Covered:

Hot food cases, Models KY, YK, SV or FR, followed by 937, 1250, 1875, 2500 and 3125, followed by HC.

Example: KY      937      HC  
                  I            II            III

I. KY, YK, SV or FR – Series designations

The KY, YK, SV and FR series hot cases are similar, except for electrical ratings, number of wells and profiles.

II. Indicates number of wells provided:

937 – 2 wells	2500 – 6 wells
1250 – 3 wells	3125 – 7 wells
1875 – 5 wells	

III. HC – Manufacturer designation, stands for “Hot Case”.

**Terms and Conditions:** The above electric hot food cases are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer’s instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided for ventilation into room or space enclosing equipment.
3. The installation shall not obstruct access for operation and servicing.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department’s Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance 4/3/07

Examined By Suzanne Anne