



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 399-05-M

**Manufacturer:**

Ferrari, 38352 La Tour Du Pin Cedex, France 38352.

**Trade Name(s):**

Precontraint® 702, 1002, 1202, 1302, 1502.

**Product:**

PVC coated fabric for covering metal frame buildings.

**Pertinent Code Section(s):**

27-514, 27-499, 27-501, 27-506, 27-507.

**Prescribed Test(s):**

RS 7-3 [NFPA 701]

**Laboratory:**

Diversified Testing Laboratories Inc.

**Test Report(s):**

Reports dated July 13, 2000, January 9, 2003, and May 10, 2004.

**Description:** Precontraint® 702, 1002, 1202, 1302, 1502 are composite textiles made of high tenacity polyester base cloth, coated with plasticized PVC with an acrylic varnish top coat. The material is suitable for use as a membrane to cover metal frame buildings and textile architecture projects. The total weights are 702-22 oz., 1002-31 oz., 1202-31 oz., 1302-40 oz., 1502-44 oz./sq. yard.

**Terms and Conditions:** The above material can be accepted as meeting the flame resistance requirements of Section 27-515 of the Code, for use in covering metal frame buildings to enclose spaces classified in occupancy groups C, E, F, G, H, or J. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance November 16, 2005

Examined By Sium Desphidan