

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 40-00-M

Report of Material and Equipment Acceptance Division

Manufacturer – Stafford Textile Limited, 2200 Lakeshore Blvd., W Suite 308, Toronto, Ontario, Canada M8V 1A4.

Trade Name – Stafftex 5505.

Product - PVC coated fabric for flex sign.

Pertinent Code Section(s) -27-499, 27-501, 27-506, 27-507, and TPPN #11/99.

Prescribed Test(s) - RS 7-3 [NFPA 701(Test Method 2)].

Laboratory - Govmark Organization Inc.

Test Report(s) - Test Report #2-2666-0 dated November 24, 1999.

Description – Stafftex 5505 is a flex sign material with 70% PVC and 30% polyester, bonding pre-coat polyester substrate with adhesion then knit coat PVC. It has a special clear top coating to enhance printing result. The material has a nominal weight of 18 oz./square yard.

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance FEB 25 2000

Examined By S Derkhdan