



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 410-06-E

**Manufacturer:** Roaster Tech  
13 Highland Drive  
Ardsley, NY 10502

**Trade Name(s):** Roaster Tech

**Product:** Indoor gas/char grill

**Pertinent Code Section(s):** 27-800, 27-826

**Prescribed Test(s):** RS 14-6 (ANSI Z83.11)

**Laboratory:** Intertek, ETL Semko Division

**Test Report(s):** 3082618-001 dated 8/22/05, 3082618-004 dated 8/22/05

**Description:** The products covered by this report are indoor gas/char grills intended for use with natural gas. All parts necessary for proper operation are included with the grills except the exhaust system and motor(s). All regulators and shutters are factory preset. The minimum clearance from sides of the grill to adjacent combustible surfaces is 12 inches and 18 inches from the backside of the grill to adjacent combustible surface. These products are to be installed in accordance with applicable local codes.

**Terms and Conditions:** The above-described gas-fired commercial grills are accepted with the following conditions:

1. Units shall use natural gas only.
2. Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

3. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical, New York City Building and Fire Codes requirements.
4. Cooking equipment shall be installed under hoods that vent to the outside and comply with Reference Standard RS 15 requirements of the New York City Building Code. The hood shall have a fire-suppression system complying with Reference Standards RS 13-2 and RS 13-3, with open heads capable of simultaneous discharge and manual release. The fire-suppression system shall be exclusively used for cooking equipment, and shall be filed with the Building Department and examined and approved by the Fire Department.
5. Adequate supply of fresh air for unit ventilation and combustion requirements shall be provided into room or space enclosing unit.
6. The installation shall not obstruct access for operation and servicing.
7. For grease removal, suitable baffle type grease filters, MEA-accepted, shall be installed.
8. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
9. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
10. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 1/15/08

Examined by 