



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 417-05-E

**Manufacturer:** Lenox Hearth Products, 1110 West Taft Avenue, Orange, CA 92865

**Trade Name(s):** Lenox

**Product:** Gas fired vented decorative fireplace appliance.

**Pertinent Code Section(s):** 27-800, RS 14-2 (ANSI Z223)

**Prescribed Test(s):** RS 14-6 (ANSI Z21.50)

**Laboratory:** OMNI (OTL)

**Test Report(s):** 116-F-365 Dated 9/19/05

**Description** – Gas Fired decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetic of a room.

| <b>Model No.</b>                  | <b>Maximum Input Rate</b> | <b>Minimum Input Rate</b> |
|-----------------------------------|---------------------------|---------------------------|
| <b>MPB3328CNM,<br/>MPB3328CNE</b> | <b>17,500</b>             | <b>13,500</b>             |
| <b>MPB3530CNM,<br/>MPB3530CNE</b> | <b>20,000</b>             | <b>16,000</b>             |
| <b>MPB4035CNM,<br/>MPB4035CNE</b> | <b>30,000</b>             | <b>24,000</b>             |
| <b>MPB4540CNM,<br/>MPB4540CNE</b> | <b>31,000</b>             | <b>24,750</b>             |

**For use with Propane Gas**

| <b>Model No.</b>  | <b>Maximum Input Rate</b> | <b>Minimum Input Rate</b> |
|-------------------|---------------------------|---------------------------|
| <b>MPB3328CPM</b> | <b>17,500</b>             | <b>13,500</b>             |
| <b>MPB3530CPM</b> | <b>20,000</b>             | <b>16,500</b>             |
| <b>MPB4035CPM</b> | <b>29,000</b>             | <b>22,300</b>             |
| <b>MPB4540CPM</b> | <b>29,000</b>             | <b>23,000</b>             |

**Recommendations:** That the above described Gas Fired vented appliance be accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electrical equipment, apparatus, materials, and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 4/27/06  
Examined by Shyam M. Prasad