



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 423-06-E

Manufacturer: Selkirk Canada Corporation, 241 Arvin Avenue, Stoney Creek, Ontario L8E2L9, Canada

Trade Name(s): Selkirk/Energy Vent B Vent

Product: Type B gas vents

Pertinent Code Section(s): 27-855, 27-884

Prescribed Test(s): RS 15-13 ANSI/UL 441 Standard for gas vents

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File MH16081, Vol.1, Sec. 1, issued June 6, 2006

Description: These are gas vents consisting entirely of factory-made parts, each designed to be assembled with the others without requiring field construction. They are intended for venting certain appliances equipped to burn only gas. The gas vents consist of two concentric pipes in which an air space is maintained between the inner, of flue gas conveying pipe, and the outer pipe.

Product Covered:

Model SD – 3”, 4”, 5”, 6”, 7” inside diameters

Model MD – 8”, 10”, 12” inside diameters

Model LD – 14”, 16”, 18”, 20”, 22”, 24”, 26”, 28”, 30”, 32”, 34”, 36” inside diameters

Terms and Conditions: The above-described factory-built Type B vents are accepted for use on the following conditions:

1. Vents shall be used in conformance with RS 15-13.
2. These gas vents shall be labeled to read, "This gas vent is for equipment that burns gas only. Do not connect to incinerator or solid or liquid fuel-burning equipment."
3. Vents shall be installed in accordance with instructions provided by the manufacturer and in accordance with the New York City Building Code for listed factory-built Type B gas vents.
4. Type B gas vents shall not be used for venting vented wall furnaces listed for use with Type BW gas vents only and shall not be used with appliances listed for use with chimneys only.
5. All shipments and deliveries of such equipment shall be accompanied by a label or tag certifying that the material shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 6/2/06

Examined By Shyam S. Khan